



SLIP TEST WORK SHEET



CUSTOMER NAME	Pro-Tek										
JOB No / TEST No											
OPERATOR	Mark Eggleton										
DATE OF TEST	01.09.20										
ON SITE / LABORATORY	Lab										
SLIP TESTER CALIBRATION No	CN712										
SLIP TESTER SERIAL No	SK1400										
ROUGHNESS METER SERIAL No	n/a										
SLIDER TYPE & CERTIFICATE No	96 SLIDER 127/18										
CONTAMINATE DESCRIPTION	Water										
SURFACE TEMPERATURE C	n/a										
TEST LOCATION / MATERIAL DESCRIPTION (including customer ref)											
Light Grey Cushion Plank											
RUN	1	2	3	4	5	6	7	8	9	10	AVE
Rz											N/A

180 DEGREE	1	2	3	4	5	6	7	8	MEAN
DRY	59	59	59	60	60	60	61	60	60
WET	46	46	45	44	44	43	43	43	43
90 DEGREE									
DRY	65	65	65	65	65	65	66	65	65
WET	50	50	50	50	49	49	49	48	49
45 DEGREE 180									
DRY	65	66	65	65	66	65	64	64	65
WET	49	49	49	49	48	48	48	48	48

TEMPERATURE ADJUSTMENT VALUE	N/A		
AVERAGE DRY	63	AVERAGE WET	46