



SLIP TEST WORK SHEET



CUSTOMER NAME	Pro-Tek										
JOB No / TEST No											
OPERATOR	Mark Eggleton										
DATE OF TEST	01.09.20										
ON SITE / LABORATORY	Lab										
SLIP TESTER CALIBRATION No	CN712										
SLIP TESTER SERIAL No	SK1400										
ROUGHNESS METER SERIAL No	n/a										
SLIDER TYPE & CERTIFICATE No	96 SLIDER 127/18										
CONTAMINATE DESCRIPTION	Water										
SURFACE TEMPERATURE C	n/a										
TEST LOCATION / MATERIAL DESCRIPTION (including customer ref)											
Natural Oak Cushion Plank											
RUN	1	2	3	4	5	6	7	8	9	10	AVE
Rz											N/A

180 DEGREE	1	2	3	4	5	6	7	8	MEAN
DRY	53	55	55	56	56	56	56	56	56
WET	44	44	43	43	43	43	42	42	43
90 DEGREE									
DRY	54	54	54	55	55	55	55	55	55
WET	45	45	44	44	44	44	43	43	44
45 DEGREE 180									
DRY	54	55	55	55	55	55	55	55	55
WET	45	45	45	45	45	44	44	44	44

TEMPERATURE ADJUSTMENT VALUE	N/A		
AVERAGE DRY	55	AVERAGE WET	44