



SLIP TEST WORK SHEET



CUSTOMER NAME	Pro-Tek
JOB No / TEST No	
OPERATOR	Hannah Sturgess
DATE OF TEST	07.06.19
ON SITE / LABORATORY	Lab
SLIP TESTER CALIBRATION No	CN569
SLIP TESTER SERIAL No	SK1400
ROUGHNESS METER SERIAL No	n/a
SLIDER TYPE & CERTIFICATE No	96 SLIDER 127/18
CONTAMINATE DESCRIPTION	Water
SURFACE TEMPERATURE C	n/a

TEST LOCATION / MATERIAL DESCRIPTION (including customer ref)
 WPC LP 6 Mia Grey

RUN	1	2	3	4	5	6	7	8	9	10	AVE
Rz											

	1	2	3	4	5	6	7	8	MEAN
BEFORE	41	38	33	36	35	34	34	33	34
AFTER									
BEFORE	40	38	36	35	35	34	34	34	34
AFTER									
BEFORE	41	37	36	36	34	34	33	33	34
AFTER									

TEMPERATURE ADJUSTMENT VALUE	
AVERAGE BEFORE	34
AVERAGE TREATED	

Machine / slider validated prior to test yes / no
 Checked pointer / arm alignment yes / no.

Machine set level yes / no.
 Pointer zero'd yes / no.

Slider conditioned yes/no
 Set contact length yes / no