



SLIP TEST WORK SHEET



CUSTOMER NAME	Pro-Tek										
JOB No / TEST No											
OPERATOR	Hannah Sturgess										
DATE OF TEST	07.06.19										
ON SITE / LABORATORY	Lab										
SLIP TESTER CALIBRATION No	CN569										
SLIP TESTER SERIAL No	SK1400										
ROUGHNESS METER SERIAL No	n/a										
SLIDER TYPE & CERTIFICATE No	96 SLIDER 127/18										
CONTAMINATE DESCRIPTION	Water										
SURFACE TEMPERATURE C	n/a										
TEST LOCATION / MATERIAL DESCRIPTION (including customer ref)											
Excel Versuvian Marble											
RUN	1	2	3	4	5	6	7	8	9	10	AVE
Rz											

	1	2	3	4	5	6	7	8	MEAN
BEFORE	16	15	13	15	15	15	15	15	15
AFTER									
BEFORE	15	15	14	15	15	15	14	14	15
AFTER									
BEFORE	16	15	13	14	14	14	14	13	14
AFTER									

TEMPERATURE ADJUSTMENT VALUE			
AVERAGE BEFORE	15		AVERAGE TREATED

Machine / slider validated prior to test yes / no
Checked pointer / arm alignment yes / no.

Machine set level yes / no.
Pointer zero'd yes / no.

Slider conditioned yes/no
Set contact length yes / no